

~~SECRET~~  
~~CONFIDENTIAL~~

8 October 1963

25X1A9a **ATTN :** Chief, OC-E  
 [REDACTED] C/FEB/OC-E  
 Chief, Real Estate & Construction Division, OL

25X1A6a File → Relocation of 250 KW Diesel Generator to  
 [REDACTED]

25X1A6a

1. In response to your telephone request, the following comments are presented in regard to the relocation of the 250 KW Fairbanks-Morse (slow speed) Diesel Generator presently installed at Site [REDACTED]

a. Because of the weight and bulk of this installation, the cost of removing, crating and transporting would be prohibitive. The engine base alone weighs 57,000 lbs.

b. The cost of re-installation, housing, etc., would more than offset the cost of several high speed generators of equal capacity.

25X1A6a

c. The design work for the expansion of electrical generating facilities at [REDACTED] has been projected on retaining this unit. The design is 80% complete. A new switchboard will be built around the existing generator switchgear (Fairbanks-Morse) as the basic unit.

d. Present policy is based on the installation of lighter units, because of smaller size and easier installation.

25X1A9a

REV DATE	23/09/81	BY	01899.5
Q210 COMP	Q21	35	TYPE 01
Q210 CLASS	PAGES	1	REV CLASS
JUST 22	NEXT REV	2011	AUTH: HR 15-2

**Distribution:**

25X1A6a

**Original - Addressee**

25X1A6a

- ① - [REDACTED] 20-63 Contract File (C&D) / RECD  
 1 - [REDACTED] File / RECD  
 2 - OL / RECD / UEB

25X1A9a

OL / RECD / UEB / [REDACTED]

(8 October 1963)

~~SECRET~~  
~~CONFIDENTIAL~~

OL 3 6381